


PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS	
Company Name:	Test Flat
Address:	The Test House Demo Steet Truro TR1 2TT



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	PAT Cornwall Limited		
Address:	4 Roseline Estate Carnie Helston Cornwall TR13 0XA	Telephone:	01209 860665
		Mobile:	07791 717358
		Email:	paul@patcornwall.co.uk
Cert Number:	PCL-000205	Signature:	
Order Number:			
File Name:	Test Customer.PAT		

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date

APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
HIPSTER HOLIDAYS - FLAT 1										
E03059643	OVEN	29/11/12	P	S	P 0.12	P 30.88	P <0.05	P <0.10	PASS	
E02968846	POWER LEAD	29/11/12	P	S	S	S	S	S	PASS	
E01307398	SKY BOX	29/11/12	P	S	S	S	S	S	PASS	
E03059642	MICROWAVE SHARP	29/11/12	P	S	P 0.08	P >50	P <0.05	P 0.22	PASS	
E03059646	AC ADAPTOR	29/11/12	P	S	S	S	S	S	PASS	
E03059647	AC ADAPTOR	29/11/12	P	S	S	S	S	S	PASS	
E03059644	RADIO CASSETTE SONY	29/11/12	P	S	S	S	S	S	PASS	
E01373789	POWER LEAD	29/11/12	P	S	S	S	S	S	PASS	
E01307404	LAMP	29/11/12	P	S	P 0.13	P >50	P <0.05	P <0.10	PASS	
E01307401	HAIR DRYER	29/11/12	P	S	S	S	S	S	PASS	
E01307391	TOASTER	29/11/12	P	S	P 0.07	P >50	P 0.75	P <0.10	PASS	
E01307403	LAMP	29/11/12	P	S	P 0.11	P >50	P <0.05	P <0.10	PASS	
P0003741	LAMP	29/11/12	P	S	P 0.10	P >50	P 0.09	P <0.10	PASS	
E01307394	LAMP	29/11/12	P	S	P 0.11	P >50	S	S	PASS	
E01373788	EXTENSION CABLE 4 WAY	29/11/12	P	P	P 0.13	P >50	S	S	PASS	
E01307395	LAMP	29/11/12	P	S	P 0.10	P >50	P <0.05	P <0.10	PASS	
E03059650	AIR CONDITIONING UNIT	29/11/12	P	S	P 0.02	P >50	P <0.05	P <0.10	PASS	
E03059648	VACUUM CLEANER NUMATIC	29/11/12	P	S	S	S	S	S	PASS	
E01307392	FRIDGE FREEZER DAEWOO	29/11/12	P	S	P 0.12	P >50	P <0.05	P <0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
E01307405	LAMP	29/11/12	P	S	S	S	S	S	PASS
E01307406	LAMP	29/11/12	P	S	P 0.12	P >50	P 0.09	P <0.10	PASS
P0003736	IRON	29/11/12	P	S	P 0.10	P >50	P 1.09	P <0.10	PASS
P0003730	KETTLE	29/11/12	P	S	P 0.07	P >50	P 2.61	P <0.10	PASS
P0003731	TELEVISION SONY	29/11/12	P	S	S	S	S	S	PASS
P0003732	DVD	29/11/12	P	S	S	S	S	S	PASS
P0003733	EXTENSION CABLE 4 WAY	29/11/12	P	P	P 0.13	P >50	S	S	PASS
P0003734	AC ADAPTOR	29/11/12	P	S	S	S	S	S	PASS
P0003735	AC ADAPTOR	29/11/12	P	S	S	S	S	S	PASS
P0003737	LAMP	29/11/12	P	S	S	S	S	S	PASS
P0003738	TIMER	29/11/12	P	S	P 0.09	P >50	P <0.05	P <0.10	PASS
P0003739	HEATER	29/11/12	P	S	P 0.08	P >50	P 0.05	P <0.10	PASS
P0003740	CLOCK RADIO	29/11/12	F	S	S	S	S	S	FAIL
DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD									
P0003742	EXTENSION CABLE 1 WAY	29/11/12	P	P	P 0.19	P >50	S	S	PASS

Total Appliances > 33

Total Appliances For Report: 33