


PAT Report Photos

For all Sites and Locations

CLIENT DETAILS	
Company Name:	Test Flat
Address:	The Test House Demo Steet Truro TR1 2TT



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	PAT Cornwall Limited		
Address:	4 Roseline Estate Carnkie Helston Cornwall TR13 0XA	Telephone:	01209 860665
		Mobile:	07791 717358
		Email:	paul@patcornwall.co.uk
Cert Number:	PCL-000205	Signature:	
Order Number:			
File Name:	Test Customer.PAT		

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date

P0003740	CLOCK RADIO	FAIL
-----------------	--------------------	-------------




PHOTO NOTES: **DAMAGED CABLE - RECABLE**

FUSE	1	CLASS	II	SOCKET		PLUG		FLEX		BODY		SWITCH	
SUITABLE FOR CONTINUED USE						SUITABLE FOR ENVIRONMENT							
VISUAL TEST DATE		01/01/80		COMBINED INSPECTION AND TEST DATE		29/12/12							
RETEST PERIOD		0		RETEST PERIOD		1							

DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD